Governament of Andhra Pradesh

Rural Water Supply & Sanitation Department

State Level Water Testing Laboratory

O/o The Project Director

State Water Supply & Sanitation Mission
"C" Block,Vasudha shelter,LIC colony,Gollapudi,Vijayawada - 521225

TEST REPORT ON CHEMICAL ANALYSIS OF WATER(DRINKING)

General Physico- Chemical Parameter

Sample received from: Dr.DVR's Sainik School

Location: 1-1,Inkollu,Bapatla District,Andhra Pradesh.

Test Report ID No :034,035/SLL/SWSM/RWS/ Private/2025-26

Description of the test items: Water Sample

Date of Collection: 08.07.2025

Date of Receipt : 08.07.2025

Date of Analysis: 08.07.2025

Date of issue

: 09.07.2025

Sl.No.	Physcio-Chemical Parameters	Units	As per IS (10500 - 2012)			
			Raw water sample test results	R.O water sample test results	Requirement (Acceptable Limit)	Permissible Limit (in the absence of alternative source)
1	Colour	Hazen	0.21	0	5	15
2	Turbidity	NTU	1.5	0	1	5
3	pH		7.23	7.06	6.5-8.5	No relaxation
4	Electrical Conductivity	micromhos/ cm	1616	125	-	<u>-</u>
5	Total Dissloved Solids	mg/L	1042	81	500	2000
6	Salinity	gm/L	0.51	0.06	0.48	1.836
7	Total Alkalinity as CaCO ₃	mg/L	428	15	200	600
8	Total Hardness as CaCO ₃	mg/L	460	22	200	600
9	Calcium as Ca++	mg/L	34	3	75	200
10	Magnesium as Mg++	mg/L	91	4	30	100
11	Flouride as F	mg/L	0.56	. 0.12	1.0	1.5
12	Chloride as Cl	mg/L	264	. 18	250	1000
13	Nitrate as NO3	mg/L	32.5	, 1.9	45	No relaxation
14	Sulphate as SO ₄ -2	mg/L	88.7	19.8	200	400
15	Total Iron as Fe	mg/L	0.18	0.09	1.0	No relaxation
16	Sodium Na+	mg/L	211.3	17.1	-	•
17	Potassium K+	mg/L	3.5	0.9	-	•
18	Silica SIO2	ma/L	30.2	1.9	-	

Note

1. The above said results are related only to the sample tested.

Date

1401LU-52

2. Sample is collected by the customer not by the laboratory.

NKOLLU, Papatla District,

hra Pradesn - 523 167

Stale Level Water Testing Leboraton , or Ropal Water Sepana Repair A.P

Secretary/Correspondent

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

RC.NO. MO MPHC/10/072/2025

DATED: \\$ /07/2025

It is certified that an inspection team headed by, Dr. Tanneru Anjali the Medical Officer of the PHC Inkollu, inspected the Dr. DVR'S SAINIK SCHOOL, 1-1, INKOLLU, BAPATLA DIST., ANDHRA PRADESH — 523167 on 14/07/2025 and based on the water test Report (Attached) bearing NO 034,035/SLL/SWSM/RWS/PRIVATE/2025-26 dated 09/07/2025 of Government of Andhra Pradesh, State Level Water Testing Laboratory, Vijayawada certified that the Dr. DVR'S SAINIK SCHOOL, 1-1, INKOLLU, BAPATLA DIST., ANDHRA PRADESH 523167, has safe drinking water facilities for the students and members of staff of the institution. The school is also maintaining hygienic sanitation conditions in the school building and the campus as per the norms prescribed by the Central, State, and U.T. Governments.

This certificate is valid till 15 /07/2026

MEDICAL OFFICER
Mandal Primary Health Centre
INKOLLU

Bapatla District, A.P.

ne Principal,
r. DVR's Sainik School,
1, INKOLLU, BAPATLA DIST,
NDHRA PRADESH- 523167

Dr. DVR'S Sainik School

1-1, INKOLLU, Bapatla District,
Andhra Pradesh - 523 167.



For: Dr. D.V.R.'S Sainik School
Secretary/Corresponderit



